

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 3225-1577:100 Page 1 of 1

CATEGORY: Fire Dampers

LISTEE: Ward Industries, 111 Riverview Drive, Monessen, PA 15062
Contact: Ryan Ward (724) 684-5500

DESIGN: Models 75 and 85 Series curtain type fire dampers. Refer to listee's data sheet for detailed product description and operational considerations.

| <i>Model</i> | <i>Max. Width</i> | <i>Max. Height</i> | <i>Max. Width</i> | <i>Max. Height</i> | <i>Position</i> |
|--------------|-----------------------|------------------------|-----------------------|------------------------|-----------------|
| 75 | 60" | 60" | 120" | 120" | Vertical |
| | 60 | 34" | 60" | 102" | Horizontal |
| | 60" | 60" | NA | NA | Horizontal |
| 85 | 36" | 41" | NA | NA | Vertical |
| | 60" | 36" | NA | NA | Vertical |
| | 36" | 41" | NA | NA | Horizontal |

RATING: 1-1/2 Hour

INSTALLATION: In accordance with the listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, rating and UL label.

APPROVAL: Listed as 1-1/2 hour fire-rated for use in heating, ventilating and air conditioning duct system passing through fire resistive walls and partitions. Suitable for vertical and horizontal installations.

10-23-01



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 13, 2002**

Listing Expires **June 30, 2003**

Authorized By: **DIANE K. AREND, Senior Deputy
Program Manager**